



IKATES, s.r.o.

Tolstého 186, 415 03 Teplice, Czech Republic

RegNo.(IČO) : 25032836



CERTIFICATION BODY No.3065

ACCREDITED BY CZECH ACCREDITATION INSTITUTE o.p.s.

ISSUES

CERTIFICATE OF PRODUCT

No. CA-09/2006

TO THE APPLICANT : Hanita CZ, Czech Republic
FOR A PRODUCT : Float glass with applied safety film SECUR GRIP
PRODUCER : Hanita Coatings, Kibbutz Hanita, Izrael

CONCLUSION :

Above mentioned certification body confirms due this certificate **the conformity** of properties of the product samples with requirements of:

ČSN EN 572-2 (2004) : Glass in building – Basic soda lime silicate glass products – Float glass

ČSN EN 356 (2000): Glass in building - Security glazing – Testing and classification of resistance against manual attack

- Float glass 3 mm with applied safety film SECUR GRIP 12 mil :

RESISTANCE CLASS EN 356 P2A

- Float glass 3 mm with both-sided applied safety film SECUR GRIP 12 mil :

RESISTANCE CLASS EN 356 P4A

ČSN P ENV 1627 (2000) : Windows, doors, shutters – Burglar resistance - Requirements and classification

Safety class 2

- Float glass 3 mm with films SECUR GRIP 4 mil EXT and SECUR GRIP 12 mil applied on the external (attacked) surface and film SECUR GRIP 12 mil applied on the internal (protected) surface

RESISTANCE CLASS EN 356 P4A

ČSN P ENV 1627 (2000) : Windows, doors, shutters – Burglar resistance - Requirements and classification

Safety class 2

Concurrently is submitted, that the producer has ensured assumptions for continual quality assurance of certified products in the plant.

Date of issue : 2006-04-28

Validity until : 2009-04-28

Ivo Matoušek

chairman of certification committee



Lubomír Hnilička

director of the company

AO/CO

Integral part of this certificate is Certification Report No. CA-09/2006 from 2006-04-28. This certificate should be used and reproduced without changes and with all appendices only.